



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19276, SPRINGFIELD, ILLINOIS 62794-9276 • (217) 782-2829

PAT QUINN, GOVERNOR

LISA BONNETT, DIRECTOR

217/782-0610

May 6, 2014

Aventine Renewable Energy, Inc.
1300 S. 2nd Street
Pekin, Illinois 61554

RECEIVED

MAY 12 2014

Re: Aventine Renewable Energy, Inc.
NPDES Permit No. IL0001953
Final Permit

NPDES PROGRAMS BRANCH
EPA, REGION 5

Gentlemen:

The Agency has received your letter dated July 10, 2013 and has reviewed your comments. However, the compliance schedule provided within Special Condition 22 of the permit was not modified as requested, because there were no specific reasons provided which would substantiate the need to extend the final compliance date for phosphorus for Outfall B01.

Attached is the final NPDES Permit for your discharge. The Permit as issued covers discharge limitations, monitoring, and reporting requirements. Failure to meet any portion of the Permit could result in civil and/or criminal penalties. The Illinois Environmental Protection Agency is ready and willing to assist you in interpreting any of the conditions of the Permit as they relate specifically to your discharge.

The Agency has begun a program allowing the submittal of electronic Discharge Monitoring Reports (NetDMRs) instead of paper Discharge Monitoring Reports (DMRs). If you are interested in NetDMRs, more information can be found on the Agency website, <http://www.epa.state.il.us/water/net-dmr/index.html>. If your facility is not registered in the NetDMR program, a supply of preprinted paper DMR Forms for your facility will be sent to you prior to the initiation of DMR reporting under the reissued permit. Additional information and instructions will accompany the preprinted DMRs upon their arrival.

The attached Permit is effective as of the date indicated on the first page of the Permit. Until the effective date of any re-issued Permit, the limitations and conditions of the previously-issued Permit remain in full effect. You have the right to appeal any condition of the Permit to the Illinois Pollution Control Board within a 35 day period following the issuance date.

Should you have questions concerning the Permit, please contact Brian W. Cox at 217/782-0610.

Sincerely,

Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK:BWC:13012201.bwc

Attachment: Final Permit

cc: Records
Compliance Assurance Section
Peoria Region
Billing
USEPA

4302 N. Main St., Rockford, IL 61103 (815)987-7760
595 S. State, Elgin, IL 60123 (847)608-3131
2125 S. First St., Champaign, IL 61820 (217)278-5800
2009 Mall St., Collinsville, IL 62234 (618)346-5120

9511 Harrison St., Des Plaines, IL 60016 (847)294-4000
5407 N. University St., Arbor 113, Peoria, IL 61614 (309)693-5462
2309 W. Main St., Suite 116, Marion, IL 62959 (618)993-7200
100 W. Randolph, Suite 10-300, Chicago, IL 60601 (312)814-6026

NPDES Permit No. IL0001953
Illinois Environmental Protection Agency
Division of Water Pollution Control
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

REASOR

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Reissued (NPDES) Permit

Expiration Date: May 31, 2019

Issue Date: May 6, 2014

Effective Date: June 1, 2014

Name and Address of Permittee:

Aventine Renewable Energy, Inc.
1300 S. 2nd Street
Pekin, Illinois 61554

Facility Name and Address:

Aventine Renewable Energy, Inc.
1300 S. 2nd Street
Pekin, Illinois 61554
(Tazewell County)

Discharge Number and Name:

Outfall 001 - Total Plant Effluent
Outfall B01 - Treated Process Wastewater
Outfall C01 - Dry Milling Waste Streams
Outfall 002 - Yeast Plant Non-Contact Cooling Water

Receiving Waters:

Illinois River
Illinois River via Outfall 001
Illinois River via Outfall 001
Illinois River

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.



Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK:BWC:13012201.bwc

NPDES Permit No. IL0001953

Effluent Limitations and Monitoring

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall(s): 001 – Total Plant Effluent
(DAF = 34.73 MGD; 45.571 MGD)

This discharge consists of:

| | | |
|------------------------------|--------------|--------------|
| 1. Non-Contact Cooling Water | DAF: | DMF: |
| 2. Boiler Blowdown | 33.46 MGD | 44.2 MGD |
| 3. Discharges from B01 | 0.14 MGD | 0.14 MGD |
| 4. Discharges from C01 | 0.87 MGD | 1.12 MGD |
| 5. Stormwater Runoff | 0.26 MGD | 0.26 MGD |
| | Intermittent | Intermittent |

| PARAMETER | LOAD LIMITS lbs/day | | CONCENTRATION | | SAMPLE FREQUENCY | SAMPLE TYPE |
|----------------------------|-------------------------|---------------|----------------|----------------|------------------|-------------|
| | DAF (DMF) | | LIMITS mg/L | | | |
| | 30 DAY AVERAGE | DAILY MAXIMUM | 30 DAY AVERAGE | DAILY MAXIMUM | | |
| Flow (MGD) | See Special Condition 1 | | | | Daily | Total |
| pH | See Special Condition 2 | | | | 2/Week* | Grab |
| Temperature | See Special Condition 3 | | | | Daily* | Continuous |
| Total Residual Chlorine*** | | | | 0.05 | 1/Month* | Grab |
| BOD ₅ | | | | Monitor Only** | 1/Month* | Composite |
| Phosphorus | | | | Monitor Only | Semi-Annual* | Composite |
| Sulfate | | | | Monitor Only | Semi-Annual* | Composite |
| Boron | | | | Monitor Only | Semi-Annual* | Composite |

Additional monitoring requirements for Outfall 001 are provided in Special Condition 16.

*For Outfall 001, during conditions when the sampling manhole will not provide representative samples due to the high water level of the receiving stream and alternative locations for representative sampling are not available, the monitoring requirements during that period for the indicated parameters shall be waived.

**See Special Condition 17.

***See Special Condition 19.

Outfall(s): B01 - Treated Process Wastewater
(DAF = 0.87 MGD; DMF = 1.1232 MGD)

| PARAMETER | LOAD LIMITS lbs/day | | CONCENTRATION | | SAMPLE FREQUENCY | SAMPLE TYPE |
|------------------------|-------------------------|---------------|----------------|---------------|------------------|-------------|
| | DAF (DMF) | | LIMITS mg/L | | | |
| | 30 DAY AVERAGE | DAILY MAXIMUM | 30 DAY AVERAGE | DAILY MAXIMUM | | |
| Flow (MGD) | See Special Condition 1 | | | | 2/Week | Total |
| Total Suspended Solids | 181.3 | 468.4 | 25 | 50 | 2/Week | Composite |
| BOD ₅ | 145.1 | 374.7 | 20 | 40 | 2/Week | Composite |
| Ammonia (as N) | See Special Condition 5 | | | | 2/Week | Composite |
| Phosphorus | 7.26* | | 1.0* | | 1/Week | Composite |

* See Special Condition 22 for compliance schedule.

NPDES Permit No. IL0001953

Effluent Limitations and Monitoring

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall(s): C01 - Dry Milling Waste Streams
(DAF = 0.26 MGD; DMF = 0.26 MGD)

This discharge consists of:

| | |
|--------------------------------|-------------|
| 1. Sand Filter Backwash | DAF: |
| 2. Reverse Osmosis Reject | 0.035 MGD |
| 3. Cooling Tower Blowdown | 0.097 MGD |
| 4. Zeolite Softener Regenerant | 0.125 MGD |
| 5. Boiler Blowdown | 0.00003 MGD |
| | * |

*Boiler Blowdown is recycled for reuse as dry milling process waters. However, there may be incidental discharges of boiler blowdown to Outfall C01.

| PARAMETER | LOAD LIMITS lbs/day | | CONCENTRATION | | SAMPLE FREQUENCY | SAMPLE TYPE |
|------------|-------------------------|---------------|----------------|---------------|------------------|-------------|
| | DAF (DMF) | | LIMITS mg/L | | | |
| | 30 DAY AVERAGE | DAILY MAXIMUM | 30 DAY AVERAGE | DAILY MAXIMUM | | |
| Flow (MGD) | See Special Condition 1 | | | | 2/Week | Total |

Outfall(s): 002 - Yeast Plant Non-Contact Cooling Water
(DAF = 1.224 MGD; DMF = 1.224 MGD)

| PARAMETER | LOAD LIMITS lbs/day | | CONCENTRATION | | SAMPLE FREQUENCY | SAMPLE TYPE |
|-------------------------|-------------------------|---------------|----------------|---------------|------------------|----------------|
| | DAF (DMF) | | LIMITS mg/L | | | |
| | 30 DAY AVERAGE | DAILY MAXIMUM | 30 DAY AVERAGE | DAILY MAXIMUM | | |
| Flow (MGD) | See Special Condition 1 | | | | 2/Week | Total |
| pH | See Special Condition 2 | | | | 2/Week | Grab |
| Temperature | See Special Condition 3 | | | | 2/Week | Single Reading |
| Total Residual Chlorine | | | | 0.05 | 1/Month | Grab |

Special Conditions

SPECIAL CONDITION 1. Flow shall be measured in units of Million Gallons per Day (MGD) and reported as a monthly average and a daily maximum on the Discharge Monitoring Report.

SPECIAL CONDITION 2. The pH shall be in the range 6.0 to 9.0. The monthly minimum and monthly maximum values shall be reported on the DMR form.

SPECIAL CONDITION 3. This facility is currently not allowed any mixing with the receiving stream in order to meet applicable water quality thermal limitations. Therefore, discharge of wastewater from this facility must meet the following thermal limitations prior to discharge into the receiving stream. The permittee may apply for the establishment of a mixing zone for thermal discharges pursuant to 35 IAC 302.102. If the Agency provides written approval of a mixing zone, then the water quality standards for temperature listed in the table below must be met at every point outside of the approved mixing zone.

| | | | | | | | | | | | | | |
|---|----|-------------|-------------|-------------|--------------|------------|-------------|-------------|-------------|--------------|-------------|-------------|-------------|
| A | | <u>Jan.</u> | <u>Feb.</u> | <u>Mar.</u> | <u>April</u> | <u>May</u> | <u>June</u> | <u>July</u> | <u>Aug.</u> | <u>Sept.</u> | <u>Oct.</u> | <u>Nov.</u> | <u>Dec.</u> |
| | °F | 60 | 60 | 60 | 90 | 90 | 90 | 90 | 90 | 90 | 90 | 90 | 60 |
| | °C | 16 | 16 | 16 | 32 | 32 | 32 | 32 | 32 | 32 | 32 | 32 | 16 |

- B. There shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions. The normal daily and seasonal temperature fluctuations which existed before the addition of heat due to other than natural causes shall be maintained.
- C. The discharge shall not cause the maximum temperature rise above natural temperatures to exceed 2.8° C (5° F).
- D. The monthly maximum value shall be reported on the DMR form.
- E. If the Agency provides written approval of a mixing zone and a methodology for determining compliance at the edge of the mixing zone, then the water temperature at the edge of the approved mixing zone shall not exceed the maximum limits in the table above during more than one percent of the hours in the 12 month period ending with any month. Moreover, at no time shall the water temperature at the edge of the mixing zone exceed the maximum limits in the table above by more than 1.7° C (3° F). Additionally, if the Agency provides written approval of a mixing zone, the temperature at the edge of the mixing zone shall be reported on the DMR.
- F. The requirements of this condition except that of Part D, are not applicable until one year from the effective date of this permit or until the Agency provides written approval of a mixing zone, whichever is earlier. The purpose of this condition is to allow the permittee time to conduct the field study described in Special Condition 4, and apply to the Agency for inclusion of a thermal mixing zone.

SPECIAL CONDITION 4. The permittee must conduct a field study during the first summer after the issuance of this permit during which the river flow is at or below the harmonic mean stream flow as determined by the Illinois State Water Survey (10,840 cfs). The river flow during this study must be at or below the harmonic mean stream flow as determined by the Illinois State Water Survey (10,840 cfs). The field study in conjunction with the modeling study must allow the delineation of the thermal plume in the Illinois River such that a relationship (model) may be determined that will provide dimensions for the mixing zone under any likely combination of effluent flows and temperatures and upstream river flows and temperatures. The report shall include the dimensions of the proposed mixing zone during 7Q10 low river flow conditions. The study plan for this work is due to the Agency within three months of the effective date of this permit. Field work may begin upon approval of the study plan by the Agency. A report outlining the findings of the study, including illustrations of the thermal plume showing isopleths is due three months upon completion of the field work. The results of the study shall be utilized to demonstrate compliance with the thermal limitations contained in Special Condition 3 for winter and summer time periods.

SPECIAL CONDITION 5. The permittee shall monitor Ammonia as N and report the concentration in mg/L and the lbs/day being discharged. If the 30 day average exceeds 100 lbs/day then the effluent concentration shall not exceed 3 mg/L on a 30 day average basis. If the daily maximum exceeds 200 lbs/day then the effluent concentration shall not exceed 6 mg/L on a daily basis.

SPECIAL CONDITION 6. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

Special Conditions

SPECIAL CONDITION 7. Samples taken in compliance with the effluent monitoring requirements for Outfall B01 and C01 shall be taken at a point representative of each discharge, but prior to mixture with Outfall 001 or any other discharges.

SPECIAL CONDITION 8. Samples taken in compliance with the effluent monitoring requirements for Outfalls 001 and 002 shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 9. The use or operation of this facility shall be by or under the supervision of a Certified Class K operator.

SPECIAL CONDITION 10. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee may choose to submit electronic DMRs (NetDMRs) instead of mailing paper DMRs to the IEPA. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/net-dmr/index.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 15th day of the following month, unless otherwise specified by the permitting authority.

Permittees not using eDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

Attention: Compliance Assurance Section, Mail Code # 19

SPECIAL CONDITION 11. The provisions outlined in 40 CFR 122.41(m) and (n) are applicable to this permit.

SPECIAL CONDITION 12. The concentration and load limits contained in the monitoring and limitation section of this permit (pages 2 and 3) shall not apply to stormwater contributions.

SPECIAL CONDITION 13. For the purposes of this permit, the discharge from Outfall C01 is limited to non-contact cooling water, reverse osmosis (R.O) reject water, softener regeneration water, sand filter backwash and boiler blowdown, free from process and other wastewater discharges.

SPECIAL CONDITION 14. Pursuant to 40 CFR 406.73, there shall be no discharge of process waters generated from the manufacturing of animal feeds (formula feed concentrate) using primarily grain and grain by-products which may be supplemented by proteins, pharmaceuticals, vitamins or mineral additives.

SPECIAL CONDITION 15. In order for the Agency to reevaluate the potential impacts of cooling water intake structure operation pursuant to 40 CFR 125.90(b), the permittee shall prepare and submit information with their NPDES Permit renewal application outlining current intake structure conditions at this facility, including a detailed description of the current intake structure operation and design, description of any operational or structural modifications from original design parameters, source waterbody flow information, actual through-screen velocity or other information as necessary.

The information shall also include a summary of historical 316(b) related intake impingement and/or entrainment studies, if any, as well as current impingement mortality and/or entrainment characterization data.

This permit may be revised or modified in accordance with any laws, regulations, or judicial orders issued pursuant to Section 316(b) of the Clean Water Act.

SPECIAL CONDITION 16. The Permittee shall conduct semi-annual monitoring of the Outfall 001 effluent and report concentrations (in mg/l) of the following listed parameters. Monitoring shall begin three (3) months from the effective date of this permit. The sample shall be a 24-hour effluent composite except as otherwise specifically provided below and the results shall be submitted on Discharge Monitoring Report Forms to IEPA unless otherwise specified by the IEPA. The parameters to be sampled and the minimum reporting

Special Conditions

limits to be attained are as follows:

| <u>STORET CODE</u> | <u>PARAMETER</u> | <u>Minimum reporting limit</u> |
|------------------------|---|------------------------------------|
| 01002 | Arsenic | 0.05 mg/L |
| 01007 | Barium | 0.5 mg/L |
| 01027 | Cadmium | 0.001 mg/L |
| 01032 | Chromium (hexavalent) (grab) | 0.01 mg/L |
| 01034 | Chromium (total) | 0.05 mg/L |
| 01042 | Copper | 0.005 mg/L |
| 00718 | Cyanide (weak acid dissociable) (grab) | 5.0 ug/L |
| 00720 | Cyanide (total) (grab not to exceed 24 hours) | 5.0 ug/L |
| 00951 | Fluoride | 0.1 mg/L |
| 01045 | Iron (total) | 0.5 mg/L |
| 01046 | Iron (Dissolved) | 0.5 mg/L |
| 01051 | Lead | 0.05 mg/L |
| 01055 | Manganese | 0.5 mg/L |
| 71900 | Mercury (grab)** | 1.0 ng/L* |
| 01067 | Nickel | 0.005 mg/L |
| 00556 | Oil (hexane soluble or equivalent) (Grab Sample only) | 5.0 mg/L |
| 32730 | Phenols (grab) | 0.005 mg/L |
| 01147 | Selenium | 0.005 mg/L |
| 01077 | Silver (total) | 0.003 mg/L |
| 01092 | Zinc | 0.025 mg/L |

Unless otherwise indicated, concentrations refer to the total amount of the constituent present in all phases, whether solid, suspended or dissolved, elemental or combined, including all oxidation states.

*1.0 ng/L = 1 part per trillion.

**Utilize USEPA Method 1631E and the digestion procedure described in Section 11.1.1.2 of 1631E.

SPECIAL CONDITION 17. For Outfall 001, if the daily maximum concentration of BOD₅ exceeds 40 mg/L then the permittee shall submit to the Agency an explanation as to the cause of the increase in BOD₅ concentration. This explanation shall be submitted in writing to the address noted in Special Condition 10.

SPECIAL CONDITION 18. This permit authorizes the use of water treatment additives that were previously approved and those that were requested as part of the permit application. The use of any new additives, or change in those previously approved by the Agency, or if the permittee increases the feed rate or quantity of the additives used beyond what has been approved by the Agency, the permittee shall request a modification of this permit in accordance with the Standard Conditions – Attachment H

SPECIAL CONDITION 19. All samples for Total Residual Chlorine shall be analyzed by an applicable method contained in 40 CFR 136, equivalent in accuracy to low-level amperometric titration. Any analytical variability of the method used shall be considered when determining the accuracy and precision of the results obtained.

For the purposes of this permit, TRC means those substances which include combined and uncombined forms of both chlorine and bromine and which are expressed, by convention, as an equivalent concentration of molecular chlorine.

SPECIAL CONDITION 20. No effluent shall contain settleable solids, floating debris, visible oil, grease, scum or sludge solids. Color, odor and turbidity must be reduced to below obvious levels.

SPECIAL CONDITION 21. Results of semi-annual sampling shall be submitted with the June and December DMR's each year.

SPECIAL CONDITION 22. Schedule of Compliance for Outfall B01 with Final Effluent Limitations for Phosphorus:

The Total Phosphorus limits specified for Outfall B01 on page 2 of this permit, shall become effective upon completion of the following compliance schedule:

Compliance ItemCompliance Date

1. Perform a study to examine if additional treatment equipment 6 Months from the Effective Date of This Permit

Special Conditions

is necessary to comply with the proposed limits.

- | | |
|---|--|
| 2. Submit an Interim Report on the findings of the study* | 8 Months from the Effective Date of This Permit |
| 3. Determine necessary equipment to achieve compliance and submit construction permit application | 12 Months from the Effective Date of This Permit |
| 4. Complete installation of necessary equipment to achieve compliance and submit Interim Report | 18 Month from the Effective Date of This Permit |
| 5. Achieve Compliance | 24 Months from the Effective Date of this Permit |

*The Interim Report shall be submitted to the IEPA to the address identified in Special Condition 10. Should the study identify that additional equipment is not needed to comply with the limits, the compliance date shall be moved to 9 months from the effective date of this permit and items 3, 4 and 5 shall be deleted from the compliance schedule.

Total Phosphorus shall be monitored until the limits specified for Outfall B01 on page 2 of this permit become effective.

REPORTING

The Permittee shall submit a report no later than fourteen (14) days following the completion dates indicated above for each numbered item in the compliance schedule, indicating, a) the date the item was completed, or b) that the item was not completed, the reason for non-completion, and the anticipated completion date.

SPECIAL CONDITION 23.STORM WATER POLLUTION PREVENTION PLAN (SWPPP)

- A. A storm water pollution prevention plan shall be maintained by the permittee for the storm water associated with industrial activity at this facility. The plan shall identify potential sources of pollution which may be expected to affect the quality of storm water discharges associated with the industrial activity at the facility. In addition, the plan shall describe and ensure the implementation of practices which are to be used to reduce the pollutants in storm water discharges associated with industrial activity at the facility and to assure compliance with the terms and conditions of this permit. The permittee shall modify the plan if substantive changes are made or occur affecting compliance with this condition.

1. Waters not classified as impaired pursuant to Section 303(d) of the Clean Water Act.

Unless otherwise specified by federal regulation, the storm water pollution prevention plan shall be designed for a storm event equal to or greater than a 25-year 24-hour rainfall event.

2. Waters classified as impaired pursuant to Section 303(d) of the Clean Water Act.

For any site which discharges directly to an impaired water identified in the Agency's 303(d) listing, and if any parameter in the subject discharge has been identified as the cause of impairment, the storm water pollution prevention plan shall be designed for a storm event equal to or greater than a 25-year 24-hour rainfall event. If required by federal regulations, the storm water pollution prevention plan shall adhere to a more restrictive design criteria.

- B. The operator or owner of the facility shall make a copy of the plan available to the Agency at any reasonable time upon request.

Facilities which discharge to a municipal separate storm sewer system shall also make a copy available to the operator of the municipal system at any reasonable time upon request.

- C. The permittee may be notified by the Agency at any time that the plan does not meet the requirements of this condition. After such notification, the permittee shall make changes to the plan and shall submit a written certification that the requested changes have been made. Unless otherwise provided, the permittee shall have 30 days after such notification to make the changes.

- D. The discharger shall amend the plan whenever there is a change in construction, operation, or maintenance which may affect the discharge of significant quantities of pollutants to the waters of the State or if a facility inspection required by paragraph H of this condition indicates that an amendment is needed. The plan should also be amended if the discharger is in violation of any conditions of this permit, or has not achieved the general objective of controlling pollutants in storm water discharges. Amendments to the plan shall be made within 30 days of any proposed construction or operational changes at the facility, and shall be provided to the Agency for review upon request.

Special Conditions

- E. The plan shall provide a description of potential sources which may be expected to add significant quantities of pollutants to storm water discharges, or which may result in non-storm water discharges from storm water outfalls at the facility. The plan shall include, at a minimum, the following items:
1. A topographic map extending one-quarter mile beyond the property boundaries of the facility, showing: the facility, surface water bodies, wells (including injection wells), seepage pits, infiltration ponds, and the discharge points where the facility's storm water discharges to a municipal storm drain system or other water body. The requirements of this paragraph may be included on the site map if appropriate. Any map or portion of map may be withheld for security reasons.
 2. A site map showing:
 - i. The storm water conveyance and discharge structures;
 - ii. An outline of the storm water drainage areas for each storm water discharge point;
 - iii. Paved areas and buildings;
 - iv. Areas used for outdoor manufacturing, storage, or disposal of significant materials, including activities that generate significant quantities of dust or particulates.
 - v. Location of existing storm water structural control measures (dikes, coverings, detention facilities, etc.);
 - vi. Surface water locations and/or municipal storm drain locations
 - vii. Areas of existing and potential soil erosion;
 - viii. Vehicle service areas;
 - ix. Material loading, unloading, and access areas.
 - x. Areas under items iv and ix above may be withheld from the site for security reasons.
 3. A narrative description of the following:
 - i. The nature of the industrial activities conducted at the site, including a description of significant materials that are treated, stored or disposed of in a manner to allow exposure to storm water;
 - ii. Materials, equipment, and vehicle management practices employed to minimize contact of significant materials with storm water discharges;
 - iii. Existing structural and non-structural control measures to reduce pollutants in storm water discharges;
 - iv. Industrial storm water discharge treatment facilities;
 - v. Methods of onsite storage and disposal of significant materials.
 4. A list of the types of pollutants that have a reasonable potential to be present in storm water discharges in significant quantities. Also provide a list of any pollutant that is listed as impaired in the most recent 303(d) report.
 5. An estimate of the size of the facility in acres or square feet, and the percent of the facility that has impervious areas such as pavement or buildings.
 6. A summary of existing sampling data describing pollutants in storm water discharges.
- F. The plan shall describe the storm water management controls which will be implemented by the facility. The appropriate controls shall reflect identified existing and potential sources of pollutants at the facility. The description of the storm water management controls shall include:
1. Storm Water Pollution Prevention Personnel - Identification by job titles of the individuals who are responsible for developing, implementing, and revising the plan.

Special Conditions

2. Preventive Maintenance - Procedures for inspection and maintenance of storm water conveyance system devices such as oil/water separators, catch basins, etc., and inspection and testing of plant equipment and systems that could fail and result in discharges of pollutants to storm water.
3. Good Housekeeping - Good housekeeping requires the maintenance of clean, orderly facility areas that discharge storm water. Material handling areas shall be inspected and cleaned to reduce the potential for pollutants to enter the storm water conveyance system.
4. Spill Prevention and Response - Identification of areas where significant materials can spill into or otherwise enter the storm water conveyance systems and their accompanying drainage points. Specific material handling procedures, storage requirements, spill cleanup equipment and procedures should be identified, as appropriate. Internal notification procedures for spills of significant materials should be established.
5. Storm Water Management Practices - Storm water management practices are practices other than those which control the source of pollutants. They include measures such as installing oil and grit separators, diverting storm water into retention basins, etc. Based on assessment of the potential of various sources to contribute pollutants, measures to remove pollutants from storm water discharge shall be implemented. In developing the plan, the following management practices shall be considered:
 - i. Containment - Storage within berms or other secondary containment devices to prevent leaks and spills from entering storm water runoff. To the maximum extent practicable storm water discharged from any area where material handling equipment or activities, raw material, intermediate products, final products, waste materials, by-products, or industrial machinery are exposed to storm water should not enter vegetated areas or surface waters or infiltrate into the soil unless adequate treatment is provided.
 - ii. Oil & Grease Separation - Oil/water separators, booms, skimmers or other methods to minimize oil contaminated storm water discharges.
 - iii. Debris & Sediment Control - Screens, booms, sediment ponds or other methods to reduce debris and sediment in storm water discharges.
 - iv. Waste Chemical Disposal - Waste chemicals such as antifreeze, degreasers and used oils shall be recycled or disposed of in an approved manner and in a way which prevents them from entering storm water discharges.
 - v. Storm Water Diversion - Storm water diversion away from materials manufacturing, storage and other areas of potential storm water contamination. Minimize the quantity of storm water entering areas where material handling equipment of activities, raw material, intermediate products, final products, waste materials, by-products, or industrial machinery are exposed to storm water using green infrastructure techniques where practicable in the areas outside the exposure area, and otherwise divert storm water away from exposure area.
 - vi. Covered Storage or Manufacturing Areas - Covered fueling operations, materials manufacturing and storage areas to prevent contact with storm water.
 - vii. Storm Water Reduction - Install vegetation on roofs of buildings within adjacent to the exposure area to detain and evapotranspire runoff where precipitation falling on the roof is not exposed to contaminants, to minimize storm water runoff; capture storm water in devices that minimize the amount of storm water runoff and use this water as appropriate based on quality.
6. Sediment and Erosion Prevention - The plan shall identify areas which due to topography, activities, or other factors, have a high potential for significant soil erosion. The plan shall describe measures to limit erosion.
7. Employee Training - Employee training programs shall inform personnel at all levels of responsibility of the components and goals of the storm water pollution control plan. Training should address topics such as spill response, good housekeeping and material management practices. The plan shall identify periodic dates for such training.
8. Inspection Procedures - Qualified plant personnel shall be identified to inspect designated equipment and plant areas. A tracking or follow-up procedure shall be used to ensure appropriate response has been taken in response to an inspection. Inspections and maintenance activities shall be documented and recorded.

Special Conditions

- G. Non-Storm Water Discharge - The plan shall include a certification that the discharge has been tested or evaluated for the presence of non-storm water discharge. The certification shall include a description of any test for the presence of non-storm water discharges, the methods used, the dates of the testing, and any onsite drainage points that were observed during the testing. Any facility that is unable to provide this certification must describe the procedure of any test conducted for the presence of non-storm water discharges, the test results, potential sources of non-storm water discharges to the storm sewer, and why adequate tests for such storm sewers were not feasible.
- H. Quarterly Visual Observation of Discharges - The requirements and procedures for quarterly visual observations are applicable to all outfalls covered by this condition.
 - 1. You must perform and document a quarterly visual observation of a storm water discharge associated with industrial activity from each outfall. The visual observation must be made during daylight hours. If no storm event resulted in runoff during daylight hours from the facility during a monitoring quarter, you are excused from the visual observations requirement for that quarter, provided you document in your records that no runoff occurred. You must sign and certify the document.
 - 2. Your visual observation must be made on samples collected as soon as practical, but not to exceed 1 hour or when the runoff or snow melt begins discharging from your facility. All samples must be collected from a storm event discharge that is greater than 0.1 inch in magnitude and that occurs at least 72 hours from the previously measureable (greater than 0.1 inch rainfall) storm event. The observation must document: color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution. If visual observations indicate any unnatural color, odor, turbidity, floatable material, oil sheen or other indicators of storm water pollution, the permittee shall obtain a sample and monitor for the parameter or the list of pollutants in Part E.4.
 - 3. You must maintain your visual observation reports onsite with the SWPPP. The report must include the observation date and time, inspection personnel, nature of the discharge (i.e., runoff or snow melt), visual quality of the storm water discharge (including observations of color, odor, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution), and probable sources of any observed storm water contamination.
 - 4. You may exercise a waiver of the visual observation requirement at a facility that is inactive or unstaffed, as long as there are no industrial materials or activities exposed to storm water. If you exercise this waiver, you must maintain a certification with your SWPPP stating that the site is inactive and unstaffed, and that there are no industrial materials or activities exposed to storm water.
 - 5. Representative Outfalls - If your facility has two or more outfalls that you believe discharge substantially identical effluents, based on similarities of the industrial activities, significant materials, size of drainage areas, and storm water management practices occurring within the drainage areas of the outfalls, you may conduct visual observations of the discharge at just one of the outfalls and report that the results also apply to the substantially identical outfall(s).
 - 6. The visual observation documentation shall be made available to the Agency and general public upon written request.
- I. The permittee shall conduct an annual facility inspection to verify that all elements of the plan, including the site map, potential pollutant sources, and structural and non-structural controls to reduce pollutants in industrial storm water discharges are accurate. Observations that require a response and the appropriate response to the observation shall be retained as part of the plan. Records documenting significant observations made during the site inspection shall be submitted to the Agency in accordance with the reporting requirements of this permit.
- J. This plan should briefly describe the appropriate elements of other program requirements, including Spill Prevention Control and Countermeasures (SPCC) plans required under Section 311 of the CWA and the regulations promulgated there under, and Best Management Programs under 40 CFR 125.100.
- K. The plan is considered a report that shall be available to the public at any reasonable time upon request.
- L. The plan shall include the signature and title of the person responsible for preparation of the plan and include the date of initial preparation and each amendment thereto.
- M. Facilities which discharge storm water associated with industrial activity to municipal separate storm sewers may also be subject to additional requirement imposed by the operator of the municipal system

NPDES Permit No. IL0001953

Special Conditions

Construction Authorization

Authorization is hereby granted to construct treatment works and related equipment that may be required by the Storm Water Pollution Prevention Plan developed pursuant to this permit.

This Authorization is issued subject to the following condition(s).

- N. If any statement or representation is found to be incorrect, this authorization may be revoked and the permittee there upon waives all rights there under.
- O. The issuance of this authorization (a) does not release the permittee from any liability for damage to persons or property caused by or resulting from the installation, maintenance or operation of the proposed facilities; (b) does not take into consideration the structural stability of any units or part of this project; and (c) does not release the permittee from compliance with other applicable statutes of the State of Illinois, or other applicable local law, regulations or ordinances.
- P. Plans and specifications of all treatment equipment being included as part of the stormwater management practice shall be included in the SWPPP.
- Q. Construction activities which result from treatment equipment installation, including clearing, grading and excavation activities which result in the disturbance of one acre or more of land area, are not covered by this authorization. The permittee shall contact the IEPA regarding the required permit(s).

REPORTING

- R. The facility shall submit an electronic copy of the annual inspection report to the Illinois Environmental Protection Agency. The report shall include results of the annual facility inspection which is required by Part I of this condition. The report shall also include documentation of any event (spill, treatment unit malfunction, etc.) which would require an inspection, results of the inspection, and any subsequent corrective maintenance activity. The report shall be completed and signed by the authorized facility employee(s) who conducted the inspection(s). The annual inspection report is considered a public document that shall be available at any reasonable time upon request.
- S. The first report shall contain information gathered during the one year time period beginning with the effective date of coverage under this permit and shall be submitted no later than 60 days after this one year period has expired. Each subsequent report shall contain the previous year's information and shall be submitted no later than one year after the previous year's report was due.
- T. If the facility performs inspections more frequently than required by this permit, the results shall be included as additional information in the annual report.
- U. The permittee shall retain the annual inspection report on file at least 3 years. This period may be extended by request of the Illinois Environmental Protection Agency at any time.

Annual inspection reports shall be mailed to the following address:

Illinois Environmental Protection Agency
Bureau of Water
Compliance Assurance Section
Annual Inspection Report
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

- V. The permittee shall notify any regulated small municipal separate storm sewer owner (MS4 Community) that they maintain coverage under an individual NPDES permit. The permittee shall submit any SWPPP or any annual inspection to the MS4 community upon request by the MS4 community.

SPECIAL CONDITION 24. The effluent, alone or in combination with other sources, shall not cause a violation of any applicable water quality standard outlined in 35 Ill. Adm. Code 302.

Attachment H

Standard Conditions

Definitions

Act means the Illinois Environmental Protection Act, 415 ILCS 5 as Amended.

Agency means the Illinois Environmental Protection Agency.

Board means the Illinois Pollution Control Board.

Clean Water Act (formerly referred to as the Federal Water Pollution Control Act) means Pub. L 92-500, as amended. 33 U.S.C. 1251 et seq.

NPDES (National Pollutant Discharge Elimination System) means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 402, 318 and 405 of the Clean Water Act.

USEPA means the United States Environmental Protection Agency.

Daily Discharge means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

Maximum Daily Discharge Limitation (daily maximum) means the highest allowable daily discharge.

Average Monthly Discharge Limitation (30 day average) means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Discharge Limitation (7 day average) means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best Management Practices (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Aliquot means a sample of specified volume used to make up a total composite sample.

Grab Sample means an individual sample of at least 100 milliliters collected at a randomly-selected time over a period not exceeding 15 minutes.

24-Hour Composite Sample means a combination of at least 8 sample aliquots of at least 100 milliliters, collected at periodic intervals during the operating hours of a facility over a 24-hour period.

8-Hour Composite Sample means a combination of at least 3 sample aliquots of at least 100 milliliters, collected at periodic intervals during the operating hours of a facility over an 8-hour period.

Flow Proportional Composite Sample means a combination of sample aliquots of at least 100 milliliters collected at periodic intervals such that either the time interval between each aliquot or the volume of each aliquot is proportional to either the stream flow at the time of sampling or the total stream flow since the collection of the previous aliquot.

- (1) **Duty to comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, permit termination, revocation and reissuance, modification, or for denial of a permit renewal application. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirements.
- (2) **Duty to reapply.** If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. If the permittee submits a proper application as required by the Agency no later than 180 days prior to the expiration date, this permit shall continue in full force and effect until the final Agency decision on the application has been made.
- (3) **Need to halt or reduce activity not a defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- (4) **Duty to mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
- (5) **Proper operation and maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up, or auxiliary facilities, or similar systems only when necessary to achieve compliance with the conditions of the permit.
- (6) **Permit actions.** This permit may be modified, revoked and reissued, or terminated for cause by the Agency pursuant to 40 CFR 122.62 and 40 CFR 122.63. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- (7) **Property rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.
- (8) **Duty to provide information.** The permittee shall furnish to the Agency within a reasonable time, any information which the Agency may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also furnish to the Agency upon request, copies of records required to be kept by this permit.

- (9) **Inspection and entry.** The permittee shall allow an authorized representative of the Agency or USEPA (including an authorized contractor acting as a representative of the Agency or USEPA), upon the presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (d) Sample or monitor at reasonable times, for the purpose of assuring permit compliance, or as otherwise authorized by the Act, any substances or parameters at any location.

(10) **Monitoring and records.**

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) The permittee shall retain records of all monitoring information, including all calibration and maintenance records, and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of this permit, measurement, report or application. Records related to the permittee's sewage sludge use and disposal activities shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503). This period may be extended by request of the Agency or USEPA at any time.
- (c) Records of monitoring information shall include:
 - (1) The date, exact place, and time of sampling or measurements;
 - (2) The individual(s) who performed the sampling or measurements;
 - (3) The date(s) analyses were performed;
 - (4) The individual(s) who performed the analyses;
 - (5) The analytical techniques or methods used; and
 - (6) The results of such analyses.
- (d) Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit. Where no test procedure under 40 CFR Part 136 has been approved, the permittee must submit to the Agency a test method for approval. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to ensure accuracy of measurements.

(11) **Signatory requirement.** All applications, reports or information submitted to the Agency shall be signed and certified.

- (a) **Application.** All permit applications shall be signed as follows:
 - (1) For a corporation: by a principal executive officer of at least the level of vice president or a person or position having overall responsibility for environmental matters for the corporation;
 - (2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
 - (3) For a municipality, State, Federal, or other public agency: by either a principal executive officer or ranking elected official.
- (b) **Reports.** All reports required by permits, or other information requested by the Agency shall be signed by a person described in paragraph (a) or by a duly authorized representative of that person. A person is a duly

authorized representative only if:

- (1) The authorization is made in writing by a person described in paragraph (a); and
 - (2) The authorization specifies either an individual or a position responsible for the overall operation of the facility, from which the discharge originates, such as a plant manager, superintendent or person of equivalent responsibility; and
 - (3) The written authorization is submitted to the Agency.
- (c) **Changes of Authorization.** If an authorization under (b) is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of (b) must be submitted to the Agency prior to or together with any reports, information, or applications to be signed by an authorized representative.
- (d) **Certification.** Any person signing a document under paragraph (a) or (b) of this section shall make the following certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

(12) **Reporting requirements.**

- (a) **Planned changes.** The permittee shall give notice to the Agency as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required when:
 - (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source pursuant to 40 CFR 122.29 (b); or
 - (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements pursuant to 40 CFR 122.42 (a)(1).
 - (3) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- (b) **Anticipated noncompliance.** The permittee shall give advance notice to the Agency of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- (c) **Transfers.** This permit is not transferable to any person except after notice to the Agency.
- (d) **Compliance schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- (e) **Monitoring reports.** Monitoring results shall be reported at the intervals specified elsewhere in this permit.
 - (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR).

- (2) If the permittee monitors any pollutant more frequently than required by the permit, using test procedures approved under 40 CFR 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - (3) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Agency in the permit.
 - (f) **Twenty-four hour reporting.** The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24-hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and time; and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. The following shall be included as information which must be reported within 24-hours:
 - (1) Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - (2) Any upset which exceeds any effluent limitation in the permit.
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Agency in the permit or any pollutant which may endanger health or the environment.

The Agency may waive the written report on a case-by-case basis if the oral report has been received within 24-hours.
 - (g) **Other noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs (12) (d), (e), or (f), at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (12) (f).
 - (h) **Other information.** Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Agency, it shall promptly submit such facts or information.
- (13) **Bypass.**
- (a) Definitions.
 - (1) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
 - (2) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - (b) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (13)(c) and (13)(d).
 - (c) Notice.
 - (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
 - (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph (12)(f) (24-hour notice).
 - (d) Prohibition of bypass.
 - (1) Bypass is prohibited, and the Agency may take enforcement action against a permittee for bypass, unless:
 - (i) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (iii) The permittee submitted notices as required under paragraph (13)(c).
 - (2) The Agency may approve an anticipated bypass, after considering its adverse effects, if the Agency determines that it will meet the three conditions listed above in paragraph (13)(d)(1).
- (14) **Upset.**
- (a) Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
 - (b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph (14)(c) are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
 - (c) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated; and
 - (3) The permittee submitted notice of the upset as required in paragraph (12)(f)(2) (24-hour notice).
 - (4) The permittee complied with any remedial measures required under paragraph (4).
 - (d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.
- (15) **Transfer of permits.** Permits may be transferred by modification or automatic transfer as described below:
- (a) Transfers by modification. Except as provided in paragraph (b), a permit may be transferred by the permittee to a new owner or operator only if the permit has been modified or revoked and reissued pursuant to 40 CFR 122.62 (b) (2), or a minor modification made pursuant to 40 CFR 122.63 (d), to identify the new permittee and incorporate such other requirements as may be necessary under the Clean Water Act.
 - (b) Automatic transfers. As an alternative to transfers under paragraph (a), any NPDES permit may be automatically

transferred to a new permittee if:

- (1) The current permittee notifies the Agency at least 30 days in advance of the proposed transfer date;
 - (2) The notice includes a written agreement between the existing and new permittees containing a specified date for transfer of permit responsibility, coverage and liability between the existing and new permittees; and
 - (3) The Agency does not notify the existing permittee and the proposed new permittee of its intent to modify or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement.
- (16) All manufacturing, commercial, mining, and silvicultural dischargers must notify the Agency as soon as they know or have reason to believe:
- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant identified under Section 307 of the Clean Water Act which is not limited in the permit, if that discharge will exceed the highest of the following notification levels:
 - (1) One hundred micrograms per liter (100 ug/l);
 - (2) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4,6 dinitrophenol; and one milligram per liter (1 mg/l) for antimony.
 - (3) Five (5) times the maximum concentration value reported for that pollutant in the NPDES permit application; or
 - (4) The level established by the Agency in this permit.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant which was not reported in the NPDES permit application.
- (17) All Publicly Owned Treatment Works (POTWs) must provide adequate notice to the Agency of the following:
- (a) Any new introduction of pollutants into that POTW from an indirect discharge which would be subject to Sections 301 or 306 of the Clean Water Act if it were directly discharging those pollutants; and
 - (b) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 - (c) For purposes of this paragraph, adequate notice shall include information on (i) the quality and quantity of effluent introduced into the POTW, and (ii) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- (18) If the permit is issued to a publicly owned or publicly regulated treatment works, the permittee shall require any industrial user of such treatment works to comply with federal requirements concerning:
- (a) User charges pursuant to Section 204 (b) of the Clean Water Act, and applicable regulations appearing in 40 CFR 35;
 - (b) Toxic pollutant effluent standards and pretreatment standards pursuant to Section 307 of the Clean Water Act; and
 - (c) Inspection, monitoring and entry pursuant to Section 308 of the Clean Water Act.
- (19) If an applicable standard or limitation is promulgated under Section 301(b)(2)(C) and (D), 304(b)(2), or 307(a)(2) and that effluent standard or limitation is more stringent than any effluent limitation in the permit, or controls a pollutant not limited in the permit, the permit shall be promptly modified or revoked, and reissued to conform to that effluent standard or limitation.
- (20) Any authorization to construct issued to the permittee pursuant to 35 Ill. Adm. Code 309.154 is hereby incorporated by reference as a condition of this permit.
- (21) The permittee shall not make any false statement, representation or certification in any application, record, report, plan or other document submitted to the Agency or the USEPA, or required to be maintained under this permit.
- (22) The Clean Water Act provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act is subject to a civil penalty not to exceed \$25,000 per day of such violation. Any person who willfully or negligently violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318 or 405 of the Clean Water Act is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Additional penalties for violating these sections of the Clean Water Act are identified in 40 CFR 122.41 (a)(2) and (3).
- (23) The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.
- (24) The Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.
- (25) Collected screening, slurries, sludges, and other solids shall be disposed of in such a manner as to prevent entry of those wastes (or runoff from the wastes) into waters of the State. The proper authorization for such disposal shall be obtained from the Agency and is incorporated as part hereof by reference.
- (26) In case of conflict between these standard conditions and any other condition(s) included in this permit, the other condition(s) shall govern.
- (27) The permittee shall comply with, in addition to the requirements of the permit, all applicable provisions of 35 Ill. Adm. Code, Subtitle C, Subtitle D, Subtitle E, and all applicable orders of the Board or any court with jurisdiction.
- (28) The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit is held invalid, the remaining provisions of this permit shall continue in full force and effect.

STATE OF ILLINOIS
ENVIRONMENTAL PROTECTION AGENCY

Subject: Aventine Renewable Energy, Inc. – Pekin – 30-Day Public Notice Comments
Data: IL0001953
Reviewed By: Brian W. Cox

Page 1 of 1

Date: 11/06/2013

30-Day Public Notice Review Notes:

No comments were received from the public during the 30-day public notice period occurring between June 10, 2013 – July 10, 2013.

The Agency received a letter 07/10/2013 dated July 10, 2013 signed by Steve Antonacci on behalf of Aventine Renewable Energy providing comments on the public noticed draft NPDES Permit. Aventine's comments were as follows:

The draft NPDES Permit will have a new phosphorous limit on Outfall B01 that will require Aventine to make modifications to the waste water treatment operations. The Agency includes a compliance schedule for this. Aventine is concerned if the initial modifications do not meet the effluent limits there may not be enough time to make significant changes within the 24 month Compliance Schedule.

Aventine requests the Agency review this and consider additional time allowance in the event the initial treatment is unsuccessful.

Aventine suggests the following modification to the Compliance Schedule:

| Compliance Item | Compliance Date |
|--|--|
| 1. Perform a study to examine if additional treatment equipment is necessary to comply with the proposed limits. | 6 months from the Effective Date of this Permit. |
| 2. Submit an Interim Report on the findings of the study. | 8 months from the Effective Date of this Permit. |
| 3. Determine the necessary equipment to achieve compliance and submit an Interim Report. | 12 months from the Effective Date of this Permit. |
| 4. Complete installation of necessary equipment to achieve compliance and submit an Interim Report. | 18 months from the Effective Date of this Permit. |
| 5. Allow a "break-in" time for treatment equipment to confirm it will meet proposed limits and submit an Interim Report. | 24 months from the Effective Date of this Permit. |
| 6. If issues arise from initial treatment equipment not meeting proposed limits allow time for alternate plan to be completed. | 30-36 months from the Effective Date of this Permit. |

Agency Response:

The request to extend the compliance schedule is based on a general concern that if Aventine's initial plan to reduce phosphorus fails, then they would need additional time to implement a plan B. The only time this would be an acceptable argument, is when the pollutant of concern does not have a proven treatment technology to reduce the pollutant. There are multiple proven technologies available to remove phosphorus (i.e. chemical (alum) addition, biological reduction, etc.) many of which do not require significant design and/or construction time.

According to 35 IAC 309.148(a), "*With respect to any discharge which is not in compliance with applicable effluent standards and limitations, applicable water quality standards or other legally applicable requirements, the permittee shall be required to take specific steps to achieve compliance therewith in the shortest reasonable period of time consistent with the guidelines and requirements of CWA and the Act.*"

The 24 month compliance schedule included in the draft permit allows sufficient time to develop a plan of treatment. Chemical precipitation is the standard treatment for phosphorus removal and would not require substantial design and/or construction time. Furthermore, if Aventine chooses to utilize biological reduction for phosphorus, the facility already has the treatment equipment necessary and would simply need to reconfigure the WWTP layout to optimize phosphorus removal. Therefore there are multiple options which are capable of being implemented within the two year time frame currently allowed within the draft permit.

Aventine has not provided any extraordinary design or construction obstacles to overcome which would substantiate the need for additional time to achieve compliance. Compliance shall occur within the shortest reasonable period of time, therefore the final compliance date for phosphorus for Outfall B01 will remain 24 months from the effective date of the permit. No changes were made to the draft permit.

Action: Issue NPDES Permit No. IL0001953.